



Certificate number: 2405720 (1)

Issued 29/05/2024

Expires 29/11/2024

## Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

### Dutypoint Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

**Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.**

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory  
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
[uk.water@kiwa.com](mailto:uk.water@kiwa.com)  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

**Certificate Issued to:**  
Dutypoint Ltd  
Unit A  
Quedgeley West Business Park  
Gloucester  
GL2 4PA  
United Kingdom



KUKreg4

# Product Certificate

Appendix to Certificate number: 2405720

The following products belong to this certificate

|  |
|--|
| <p><b>PRODUCT DESCRIPTION</b><br/> Dutypoint 'VMV' range of cold water supply booster sets, incorporating 2 to 8 pumps with a modular stainless steel manifold system. VMV2, VMV3 and VMV4 pump sets are available with DN80 to DN150 manifolds depending on application. VMV5, VMV6, VMV7 and VMV8 pump sets are available with DN150 to DN200 manifolds, depending on application. The product incorporates gate valves on the suction and discharge manifolds, and non-return valves, expansion vessels, isolation valves, a pressure gauge and transducers on the discharge manifold.<br/> ATS3 – Without Production Surveillance.</p> |
| <p><b>MODEL(S)</b><br/> VMV(i)-(ii)-(iii)(iv)</p> <p>Where:<br/> (i) = Number of pumps 2-8<br/> (ii) = Nominal Flow Rate (l/sec)<br/> (iii) = Pump/Inverter Manufacturer denoted by the letter V or H,<br/> (iv) = Motor size (kWx10)</p> <p>As an example:<br/> VMV2-15-V110</p> <p>Number of pumps = 2<br/> Nominal flowrate (l/sec) = 15<br/> Pump inverter manufacturer = V for Vasco, H for Hydrovar<br/> Motor size (kW x 10)</p>  |
| <p><b>SIZE:</b><br/> Flanged manifold connections on suction and discharge manifolds Sizes 80mm to 200mm.</p>  |
| <p><b>SCOPE:</b><br/> Manufacturer recommended maximum working pressure 16 Bar &amp; maximum operating temperature: Cold water use only.<br/> Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.</p>  |
| <p><b>MARKING</b><br/> Dutypoint, model number and technical information on adhesive label on control box.</p>   |
| <p><b>MATERIALS</b><br/> Dutypoint, model number and technical information on adhesive label on control box.</p>   |
| <p><b>BACKFLOW PROTECTION NOTES</b><br/> N/A.</p>  |
| <p><b>ADDITIONAL NOTES</b><br/> All water contact &amp; exposed components satisfy opacity requirements.</p> <p>Notification should be given in writing of the proposed installation of this fitting to the local Water Supplier prior to its installation. The fitting shall not be installed until consent is given by the Water Supplier in line with Regulation 5 of the Water Supply (Water Fittings) Regulations 1999 or the Water Supply (Water Fittings) Regulations (Northern Ireland) 2009, or Byelaw 5 of the Water Supply (Water Fittings) (Scotland) Byelaws 2014.</p>  |

## Extra Notes