



Certificate number: 2405719 (1)

Issued 28/05/2024

Expires 28/11/2024

## Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

### Dutypoint Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

**Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.**

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory  
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
[uk.water@kiwa.com](mailto:uk.water@kiwa.com)  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

**Certificate Issued to:**  
Dutypoint Ltd  
Unit A  
Quedgeley West Business Park  
Hardwicke  
Gloucester  
GL2 4PA  
United Kingdom



KUKreg4

# Product Certificate

Appendix to Certificate number: 2405719

The following products belong to this certificate

<p><b>PRODUCT DESCRIPTION</b> Range of electromagnetic water conditioning units with nickel-plated cast-iron bodies and NBR 'O'-rings. ATS3 – Without Production Surveillance.</p>
<p><b>MODEL(S)</b> ¾" BSP (F) (DN20): EC20-150, EC20-180 &amp; EC20-200 models. 1" BSP (F) (DN25): EC25. 1¼" BSP (F) (DN32): EC32. 1½" BSP (F) (DN40): EC40. 2" BSP (F) (DN50): EC50. 2 ½" BSP (F) (DN65): EC65. 3" BSP (F) (DN80): EC80. 4" BSP (F) (DN100): EC100.</p>
<p><b>SIZE:</b> See model.</p>
<p><b>SCOPE:</b> Manufacturer recommended maximum working pressure 16 Bar &amp; maximum operating temperature: Cold water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.</p>
<p><b>MARKING</b> Dutypoint, contact details, model, flow rate, pressure and technical information on main body and electrical box.</p>
<p><b>MATERIALS</b> Non-metallic materials assessed (BS6920) to point of discharge/to backflow prevention device.</p>
<p><b>BACKFLOW PROTECTION NOTES</b> A compliant single check valve or some other no less effective backflow prevention device providing backflow prevention protection to at least fluid category two shall be fitted at the point of connection(s) between the water supply and the fitting or appliance.</p>
<p><b>ADDITIONAL NOTES</b> All water contact &amp; exposed components satisfy opacity requirements. The fitting is to be so installed as to be readily accessible for examination, test, maintenance, replacement or operation. Water Undertakers cannot be responsible for the quality of water passed from these fittings. In accordance with schedule 2 paragraph 27 of the Water Supply (Water Fittings) Regulations 1999 in England and Wales, the Water Supply (Water Fittings) Regulations (Northern Ireland) 2009, and the Water Supply (Water Fittings) (Scotland) Byelaws 2014, a drinking water tap shall be installed upstream of this fitting. However, if it can be demonstrated that the water once it has passed through this water fitting remains wholesome and meets national standards, water suppliers may not require the installation of a drinking water tap upstream of this water fitting.</p>

## Extra Notes